

FORM 128
5-63

USE PREVIOUS
EDITIONS

Approved For Release 2002/10/29 : CIA-RDP66B00597R000400040140-3

AFG 1-65

CLASSIFIED MESSAGE

DATE 0753Z 02 JUL 65

SECRET

ROUTING		
1	<i>Follow</i>	9
2	"	10
3	<i>DFA</i>	11
4	<i>CC</i>	12
5	<i>SS</i>	13
6	<i>Intel</i>	14
7	<i>SD</i>	15
8	<i>RB</i>	16

TO : DIRECTOR

FROM : 25X1D

ACTION:

INFO :

IMMEDIATE

TOR: 0809Z 02 JUL 65

25X1D

OSA 1-20 E

IN 95747

TO

INFO

CITE

INTEL SECUR

25X1D

25X1D

25X1C

1. PHOTO LAB UNABLE TO PROCESS TAKE DUE TO INSUFFICIENT WATER IN LAB STORAGE TANKS. WATER SOURCE CONTAMINATED BY PIPE RUST FROM WITHIN THE WELL AND WELL PUMP INOPERATIVE. CONTAMINATED SOURCE HAS NOT BEEN USED SINCE 30 JUNE. STORAGE TANKS HAVE BEEN REPLENISHED THROUGH BASE WATER SUPPLY. DUE TO NUMEROUS F-101 AND F-104 MISSIONS PROCESSED OVER THE PAST TWO DAYS THE WATER SOURCE HAS BEEN DIMINISHED TO AN ESTIMATED ONE HUNDRED TEN TONS. RATE OF REFILLING FROM BASE SOURCE INSUFFICIENT TO FILL TANKS FOR THE PROCESSING OF IDEALIST TAKE, MISSION C355C, PRIOR TO 3/0400Z.

25X1C

2. ATTEMPTING TO REFILL TANKS IN ANTICIPATION OF PROCESSING MISSION C365C. WILL ADVISE ASAP

25X1C

3. ESTIMATES PUMP AND WELL WILL BE OPERATIONAL ON 5 JULY.

END OF MESSAGE

Approved For Release 2002/10/29 : CIA-RDP66B00597R000400040140-3

GROUP 3
EXCLUDED FROM AUTO-
DOWNGRADING AND
DECLASSIFICATION

REPRODUCTION BY OTHER THAN THE ISSUING OFFICE IS PROHIBITED. COPY NO. 4